

GOOD PRACTICES IN SME

Replacing the heat source



Designed by freepik

The following document was developed using European Union financing as part of the “Technical support for the promotion of energy audits and energy efficiency investments in small and medium-sized enterprises in Poland”. The opinions presented in this document should not be treated as the official stance of the European Union.

The project was financed by the European Union as part of Structural Reform Support Programme (SRSP) and realized by the Polish National Energy Conservation Agency (KAPE SA) in cooperation with the European Commission on behalf of the Ministry of Climate and Environment.

Why should the heat source be replaced?

The heat source (usually a boiler) is the key element of the entire central heating installation. The heat source has the greatest influence on the performance of the entire heating system and therefore on the cost of heating.

We usually replace the boiler with the most modern boiler with a higher efficiency. Sometimes a conventional boiler is replaced with a zero-emissions heat pump, characterized by the lowest per unit cost of heating (but also high investment costs). Both enable decrease heating costs while also decreasing CO₂ and pollutant emissions into the atmosphere. Replacing a coal boiler with a gas or biomass boiler also lowers greenhouse gas emissions.

The need to replace the heat source can also arise out of malfunctions of the old installation or stricter norm on fuel and boilers in the given territory.

Selecting a boiler, attention should be paid to its energy performance class, located on the energy label



Pic. 2 AleKoty: coal boiler



Pic. 3 kociolgrzejnik: gas boiler



Pic. 1 swatt: heat pump

Example for replacing a boiler with a high-performance boiler

The hot water production plant uses an old coal boiler with $P=50$ kW and an efficiency of $\eta_o=60\%$. What are the annual savings from replacing it with a high efficiency ($\eta_n=85\%$) boiler fired with eco-pea coal with a calorific value of $W_o=25$ MJ/kg and a price of $k=800$ PLN/t? The boiler is in operation about $t=4000$ hours annually.

The annual cost of feeding the solid boiler can be determined using the following formula:

$$\text{cost} = \frac{0,36 \cdot P [\text{kW}] \cdot t [\text{h}] \cdot k \left[\frac{\text{PLN}}{\text{t}}\right]}{W_o \left[\frac{\text{MJ}}{\text{kg}}\right] \cdot \eta [\%]}$$

Annual cost of fuel for the old boiler:

$$\frac{0,36 \cdot 50 \text{ kW} \cdot 4000 \text{ h} \cdot 800 \text{ PLN/t}}{25 \text{ MJ/kg} \cdot 60} = 38400 \text{ PLN}$$

Annual cost of fuel for the new boiler:

$$\frac{0,36 \cdot 50kW \cdot 4\,000\,h \cdot 800\,PLN/t}{25\,MJ/kg \cdot 85} = 27\,106\,PLN$$

Annual savings generated by replacing the old boiler with a high-performance boiler:

$$38\,400\,PLN - 27\,106\,PLN = 11\,294\,PLN$$

Source: KAPE

Example for replacing a boiler with a heat pump

A building is heated by a gas boiler with $P = 80\,kW$ and an efficiency of $\eta = 90\%$. The boiler is operation about $t = 3\,500$ hours and is powered by natural gas with a calorific value of $W_o = 34\,MJ/m^3$ which costs $k = 2,30\,PLN/m^3$. How much will the building's owner save if the boiler is replaced with a heat pump with an average $COP = 2,5$? The average cost of electricity is $k_e = 0,55\,PLN/kWh$.

The annual cost of feeding the gas boiler can be calculated using the formula:

$$cost = \frac{360 \cdot P [kW] \cdot t [h] \cdot k \left[\frac{PLN}{m^3}\right]}{W_o \left[\frac{MJ}{m^3}\right] \cdot \eta [\%]}$$

Annual fuel cost for the gas boiler:

$$\frac{360 \cdot 80kW \cdot 3\,500\,h \cdot 2,30\,PLN/m^3}{34MJ/m^3 \cdot 90} = 75\,765\,PLN$$

The annual cost of powering the heat pump can be calculated using the formula:

$$cost = \frac{P [kW] \cdot t [h] \cdot k_e \left[\frac{PLNzł}{kWh}\right]}{COP}$$

Annual cost of powering the heat pump:

$$\frac{80\,kW \cdot 3\,500\,h \cdot 0,55\,PLN/kWh}{2,5} = 61\,600\,PLN$$

Annual savings generated by replacing the gas boiler with a heat pump:

$$75\,765\,PLN - 61\,600\,PLN = 14\,165\,PLN$$

Source: KAPE